



## Conveyance Owner/Contractor Notification

### RE: Overdue Annual Safety Tests.

The Northwest Colorado Council of Governments (NWCCOG) – Elevator Inspection Program (EIP) has found that numerous conveyance(s) within the NWCCOG jurisdiction have been operating without having the required annual safety test(s) performed.

Colorado Conveyance Regulation 7 C.C.R. 1101-8, Section 2-3-1-3 states that if an annual safety test is past due, then a Temporary Certificate of Operation (TCO) **MAY** be issued for a period as determined by the administrator, affording the conveyance owner or conveyance responsible party, time to schedule such test to be completed by a Licensed Conveyance Contractor.

There is no provision that allows for a conveyance to operate if the required annual safety test is overdue by more than one year.

Category I Safety Tests must be completed in the same month each year, in the month aligned with the 5 Year Witnessed Test.

Therefore, effective immediately, if multiple annual safety tests have been missed, our office will be forced to shut down the unit in question, when such occurrence is identified during the course of our annual inspection.

Please verify that your safety tests are current to avoid possible enforcement actions that could result in your conveyance being shut down.

A copy of this notification has been sent to all conveyance owners, conveyance responsible parties and conveyance contractors.

Please feel free to contact me with any questions.

*David Harris*  
David L. Harris (EIP) Director

#### MEMBER

#### JURISDICTIONS

City of Glenwood  
Springs

City of Steamboat  
Springs

Town of Hayden

#### EAGLE COUNTY

Avon  
Basalt  
Eagle  
Gypsum  
Minturn  
Red Cliff  
Vail

#### GRAND COUNTY

Fraser  
Granby  
Grand Lake  
Hot Sulphur Springs  
Kremmling  
Winter Park

#### JACKSON COUNTY

Walden

#### PITKIN COUNTY

Aspen  
Snowmass Village

#### SUMMIT COUNTY

Blue River  
Breckenridge  
Dillon  
Frisco  
Montezuma  
Silverthorne