



SUSPENSION MEANS REPLACEMENT CONVEYANCE PERMIT

A separate Permit Application is required for each conveyance.

Permit # _____

This area is to be completed by EIP Office

Permit Expiration Date _____

Date Issued _____

** Permits expire six months for alterations **
IF PERMIT EXPIRES BEFORE WORK BEGINS
A NEW PERMIT SUBMITAL MUST BE MADE

Receipt# _____ Date Paid _____

Permit Fee _____

Approval Signature _____

Job Address _____ City/Town: _____ Zip: _____

Job Name _____

Job Mailing Address _____

Job Phone # _____ Email _____

Elevator Company _____ State License Number _____

Mailing Address _____

Phone # _____ Email _____

ALTERATION – Suspension Means Replacement

Conveyance Unit/Serial #: _____

Suspension Type:

State of Colorado Registration ID# CP _____ - _____

- Governor Rope
- Rope (Steel Wire/Wire)
- Belted Suspension

MEETS ALL REQUIREMENTS OF A17.1 2022 SECTION 8.6.3

Size: _____

NOTICE

I hereby certify that I have examined this application and know the same to be true and correct. All provisions of laws and ordinances governing this type of work will be complied with whether specified herein or not. The granting of a permit does not presume to give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction.

Licensed Contractor Signature _____ Date _____

Conveyance plan review and field inspections will be conducted by NWCCOG Elevator Inspection Program.

ALTERATION OR MODIFICATION FEES

\$150 = Suspension Means Replacement Permit

Re-submittal Fee for Expired Permits = \$75

Work performed/started without permit = double the permit fee

TOTAL FEE

PAYMENT: Credit/Debit Card or Electronic Check -

www.nwccog.org/programs/elevator-inspection-program

Schedule acceptance inspections by emailing NWCCOG at Elevator@NWCCOG.org
An approved Permit does not constitute approval on final inspection.

ACCEPTANCE TEST AND CHECKLIST

Suspension Monitoring: Pass Fail N/A

Anti-rotation device installed: Yes No N/A

Wire Rope Fastening Hatch Plate: Pass Fail N/A

Steel Wire Ropes Lightly Lubricated: Yes No N/A

Slack Rope Switch: Pass Fail N/A

Rope Data Tag Securely Fastened to Suspension Means: Yes No

Governor Rope Pull Trough: Pass Fail

Govenor Rope Tags Installed on Each Renewal: Yes No N/A

Car or Counterweight Safety Test: Pass Fail

Test Tags In Place: Yes No

Roped Tentioned within 10% of Highest Tention: Yes No

MCP Log Updated: Yes No

When passed, signed and dated below shall signify an official Certificate of Operation will be issued and this conveyance is considered to have a CO:

Date _____ Passed Failed and need to return

Inspector Sign _____

Print _____

Date _____

Elevator Company Sign _____

Print _____

Date _____

NOTES/VIOLATIONS: